



NOTES:

1. 4" MIN. SUB-BASE (CONCRETE, ASPHALT, OR 90-95% COMPACTED $\frac{3}{4}$ " MINUS AGGREGATE INSTALLED IN 2-2" LIFTS), SLOPE 2% MAX.
2. POURED-IN-PLACE RUBBER BASE LAYER (DEPTH VARIES PER MANUFACTURER'S RECOMMENDATION)
3. POURED-IN-PLACE WEAR COURSE, (2% MAX SLOPE). WEAR COURSE DEPTH VARIES BASED ON PRODUCT SOLD
4. DESIGNATED BEVELED EDGE
5. TURN DOWN
6. 1/4 " WIDE X $\frac{1}{2}$ " DEEP KEYWAY CUT IN OR FORMED IN WHEN POURED AROUND PERIMETER
7. APPROPRIATE AGGREGATE SUB-BASE, COMPACT BETWEEN 90-95%

THE 1:12 SLOPE AS PER ADA GUIDELINES IS REQUIRED AT (1) 6' ENTRANCE TO RECREATIONAL AREA.
ALL REMAINING SLOPE MAY BE AT MINIMUM 1:3

NOTE:

ALL INFORMATION SHOWN IS SUGGESTED. DUE TO APPLICATION VARIANCES, IT IS THE RESPONSIBILITY OF THE ENGINEER OF RECORD TO PROVIDE ALL INFORMATION REQUIRED TO SUIT LOCAL BUILDING CODES AND REGULATIONS. THIS DETAIL IS FOR REPRESENTATIVE PURPOSES ONLY AND SHOULD NOT BE SOLELY USED FOR CONSTRUCTION PURPOSES UNLESS IT HAS BEEN CERTIFIED AND SEALED BY A QUALIFIED ENGINEER.



Rubberway, Inc.
4000 Barranca Pkwy,
Ste 250
Irvine, CA 92604
Phone. 877.288.0045
rubberway.com

SHEET NAME: RUBBERWAY PERVIOUS PAVEMENT
OVER ASPHALT/CONCRETE WET CONDITIONS

SHEET: DETAIL NO. 12

APPROVED BY: KA **DRAWN BY:** JAB **DATE:** 2/6/15

DUE TO VARIANCES IN LOCAL CODES, CONSTRUCTION PRACTICES AND REQUIREMENTS, ALL DETAILS SHALL BE CONSTRUCTED IN ACCORDANCE WITH SUCH LOCAL CODES, CONSTRUCTION PRACTICES AND REQUIREMENTS REGARDLESS OF DETAIL CONSTRUCTION SHOWN IN DRAWING. RUBBERWAY, INC. RESERVES THE RIGHT TO CHANGE SPECIFICATIONS SHOWN WITHOUT NOTICE. ALL CHANGES TO SPECIFICATIONS CAN ONLY BE APPROVED BY RUBBERWAY, INC.